

CERTIFICATE

The company

**Zhejiang Shentai
Solar Energy Co., Ltd**
Haining Yuanhua
Industry Zone
ZHEJIANG 314416
PEOPLE'S REPUBLIC OF CHINA

with its production site in

Zhejiang

hereby receives the confirmation that the product/s

Solar collectors

of the type


**SCM-Series
SCM 12, SCM 15, SCM 20**

conforms to

**DIN EN 12975-1:2006-06
DIN EN 12975-2:2006-06**

Specific CEN KEYMARK Scheme Rules for Solar Thermal Products

and is granted the licence to use the marks



in conjunction with the Registration No. below.

Registration No.: 011-7S297 R



DAP-ZE-2460.00

This certificate remains valid as long as the required surveillance conditions will be passed with a positive result for the assessment.


See annex for further information.

DIN CERTCO Gesellschaft für
Konformitätsbewertung mbH
Alboinstraße 56, 12103 Berlin



2007-12-04

Dipl.-Ing. Dipl.-Wi.-Ing. Sören Scholz
- Acting Head of Certification Body -



Annex

to the Certificate with Registration No. 011-7S297 R, dated 2007-12-04

Technical data

See data sheet, part of the test report of 2007-11-08

Note(s):

- The freeze resistance test according to DIN EN 12975-2, clause 5.8 was not necessary. According to the manufacturer's declaration, the certified solar collectors may be used in frost exposed areas only in combination with appropriate frost protection mixtures.
- The optional impact resistance test according to DIN EN 12975-2, clause 5.10 was not carried out.

Testing laboratory / Inspection body

Fraunhofer Institut für
Solare Energiesysteme (ISE)
Therm. Anlagen u. Komponenten
Heidenhofstr. 2
79110 Freiburg

Test report(s)

KTB No. 2007-41-k-en dated 2007-11-08